



From: North America Product Management Team
To: North America OEM and Distribution Customers
Date: April 5, 2021
Subject: ARGUS – Factory Charged Pressure Identification Tag – Part # 74203!

PRODUCT BULLETIN

Dear Valued Customer,

Tecumseh hereby advises that a pressure identification tag – part # 74203 will be attached to each ARGUS condensing unit effective from the date of this product bulletin.

The pressure identification tag, as shown in the image below, indicates that the unit is pre-charged from the factory with a holding charge of dry air / nitrogen at between 20 – 50 PSIG.



Since every manufacturer is different, we want to caution the customer / contractor / installer that the ARGUS condensing units are supplied with a holding charge of dry air / nitrogen from the factory and with service valves set in the closed position. The charge ensures that the units do not accumulate moisture when stored or shipped. All standard safety practices and regional laws and regulations as prescribed must be followed when installing an ARGUS condensing unit. ARGUS condensing units can only be installed by qualified and accredited service technicians.

Support / Questions

If you have questions that are not addressed in this bulletin, please contact your local Tecumseh Sales Representative or Technical Service Team members at (800.211.3427) or email at technical.service@tecumseh.com.