

POLICY BULLETIN

Tecumseh Compressor Company
Compressor Group



Tecumseh

**SUBJECT: Application Precautions Relating to the Usage
of Model Compressors in PTAC and Water to
Air Heat Pumps**

PB-117
PAGE: 1 of 1
REV DATE: 4/25/2007

Issued: November, 26 1963

Field experience with room cooler compressors utilized in rapid cycling systems strongly suggests that special measures must be taken to avoid premature mounting spring failure.

Engineering Policy No. [EP-7](#), *AJ Room Cooler Compressor Application to PTAC and Water to Air Heat Pumps*, outlines the internal and external mounting requirements of AJ compressors in these systems.